



GENERAL NOTES:

- ① FALL THROUGH TABLET FEEDER FROM INLET INVERT TO OUTLET INVERT IS ONE INCH ±3/8".
- ② FINISHED GRADE MUST BE MAINTAINED AT LEAST SIX INCHES BELOW TOP OF LID.
- ③ FEEDER BASE HEIGHT MAY BE REDUCED IN SIX INCH INCREMENTS.
- ④ WHERE TABLET FEEDER IS INSTALLED WITHOUT MOUNTING BRACKETS, INSTALL ON FOUR INCH SAND OR FINE GRAVEL LEVELING PAD.

PROJECT ENGINEER'S APPROVAL:
I (WE) HEREBY CERTIFY THAT THIS DRAWING HAS BEEN CHECKED AND IS APPROVED FOR USE IN CONFORMITY WITH THE CONTRACT DOCUMENTS.

DATE: _____
NAME: _____

CONTRACTOR'S CERTIFICATION:
I (WE) HEREBY CERTIFY THAT THIS DRAWING HAS BEEN CHECKED AND IS APPROVED FOR USE IN CONFORMITY WITH THE CONTRACT DOCUMENTS.

DATE: _____
NAME: _____

CRITICAL DIMENSIONS			
A	0'-10 1/2"	J	0'-0 1/2"
B	1'-0" TO 1'-6"	K	0'-8"
C	2'-1 1/2"	L	0'-3 1/2"
D	0'-5"	M	0'-10"
E	0'-5 1/4"	N	1'-8"
F	0'-1 3/4" (TYP)	O	
G	0'-2" (TYP)	P	
H	0'-4 1/2" (TYP)	Q	
I	0'-1 1/2"	R	

TOLERANCES
NOMINAL DIMENSIONS ARE SHOWN AND MAY VARY ±3/8" FOR ROTOMOLDED COMPONENTS.

U.S. AND FOREIGN PATENTS PENDING		REVISION DATE: 8-12-98	DESIGN: A
		APPROVED BY: JMM	ED
	BIO-DYNAMIC MODEL XT 2000 TABLET FEEDER	DATE: 10-2-97	
		SCALE: NTS	
© MCMXCVII	<small>THIS DRAWING IS THE PROPERTY OF NORWECO. IT IS TO BE USED ONLY FOR THE PROJECT AND NOT TO BE REPRODUCED OR COPIED IN ANY MANNER WITHOUT WRITTEN PERMISSION FROM NORWECO.</small>		PC-5-9501